



# State Hygienic Laboratory

## The University of Iowa

Date of report: 12-21-2010

|||||  
JON MARTENS

ATLANTIC MUNICIPAL UTILITIES  
15 W 3RD STREET  
PO BOX 517  
ATLANTIC IA 50022

Sample Number 2010047094  
Date Received 12-16-2010  
Project  
Date Collected 12-15-2010 10:30  
Collection Site well #6  
Collection Town Atlantic  
Description water  
Reference  
Collector PARROTT TROY  
Phone (712) 243-1395  
Purchase Order

Comments

Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.

### Results of Analyses

#### GC/MS 524.2 Volatiles

Analyte	Concentration ug/L	Quantitation Limit ug/L
Tetrachloroethene	<0.5 J	0.5
Comments	J - Please note that this compound was observed below the quantitation limit in the analysis of this sample.	

Date Analyzed: 12-17-2010  
Method: EPA 524.2

Analyzed at: Iowa City

Analyst: LL  
Verified: CR

#### Description of units used within this report

ug/L - Micrograms per Liter

Quant Limit - Lowest concentration reliably measured

The results of this report relate only to the items analyzed. This report shall not be reproduced except in full without the written approval of the laboratory.

Iowa Environmental Laboratory IDs are: Ankeny #397, Iowa City #027, Lakeside #393.

If you have any questions please call Client Services at 800/421-IOWA (4692) or 319/335-4500. Thank you.

A72Q

40479939



Superfund

1.0

0000